

5.3.12 Main Commercial Heating and Cooling Equipment as of 1995, 1999, and 2003 (Percent of Total Floorspace) (1)

<u>Heating Equipment</u>	<u>1995</u>	<u>1999</u>	<u>2003 (2)</u>	<u>Cooling Equipment</u>	<u>1995</u>	<u>1999</u>	<u>2003 (2)</u>
Packaged Heating Units	29%	38%	28%	Packaged Air Conditioning Units	45%	54%	46%
Boilers	29%	29%	32%	Individual Air Conditioners	21%	21%	19%
Individual Space Heaters	29%	26%	19%	Central Chillers	19%	19%	18%
Furnaces	25%	21%	30%	Residential Central Air Conditioners	16%	12%	17%
Heat Pumps	10%	13%	14%	Heat Pumps	12%	14%	14%
District Heat	10%	8%	8%	District Chilled Water	4%	4%	4%
Other	11%	6%	5%	Swamp Coolers	4%	3%	2%
				Other	2%	2%	2%

Note(s): 1) Heating and cooling equipment percentages of floorspace total more than 100% since equipment shares floorspace. 2) Malls are no longer included in most CBECs tables; therefore, some data is not directly comparable to past CBECs.

Source(s): EIA, Commercial Building Characteristics 1995, Oct. 1998, Tables B34 and B36 for 1995, and EIA, Commercial Building Characteristics 1999, Aug. 2002, Tables B33 and B34 for 1999; and EIA, 2003 Commercial Buildings Energy Consumption and Expenditures: Consumption and Expenditures Tables, June 2006, Tables B39 and B41 for 2003.